

Pleasantville Building Reopening Checklist

Totals

Building	% COMPLETE	DONE	NYS Reopening Recommendation	NOTES
Lienhard Hall		<input type="radio"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="radio"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Classroom Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Red/Green System in place
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	50%	<input type="radio"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	20%	<input type="radio"/>	Exceeds	Recommended Areas Submitted
Dyson Hall		<input type="radio"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	As a Research Space HVAC systems have been operating 24-7 since March

Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	Temperatures were mainly between 70F-72F. AC Operational.
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	As a Research Space HVAC systems have been operating 24-7 since March
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Classroom Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Red/Green System in place
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
UV Light Analysis	50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	20%	<input type="checkbox"/>	Exceeds	Recommended Areas Submitted
Choate House		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	System Checked and Working
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	Lenox Unit Found not operating, unit has been fixed
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	50%	<input type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	

Office Occupancy Reduced	N/A	<input checked="" type="checkbox"/>	Exceeds	Office Occupancy Responsibility of Department
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Admin Building		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	System Checked and Working
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	50%	<input type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Office Occupancy Reduced	N/A	<input checked="" type="checkbox"/>	Exceeds	Office Occupancy Responsibility of Department
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended at this Time
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended at this Time

Environmental Classroom		<input type="radio"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	System Checked and Working
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="radio"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Signage Installation 8-13
Classroom Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Red/Green System in place
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Field House		<input type="radio"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	2 Units not Communicating
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	100%	<input checked="" type="checkbox"/>	Exceeds	
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis

Run Water Fountains / Bottle Fillers	100%	✓	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	✓	Meets Mandate	Signage Installation 8-17
Occupancy Reduced	100%	✓	Exceeds	Athletics has plan for occupancy reduction
Disinfected Before Occupancy	100%	✓	Exceeds	
Hand Sanitizer Installed	100%	✓	Meets Mandate	
Building Circulation Plan	100%	✓	Exceeds	Not Applicable
UV Light Analysis	100%	✓	Exceeds	Not Recommended
AtmosAir Analysis	100%	✓	Exceeds	Not Recommended
Ianiello Field House		○		
BMS Check - Mechanical Equipment	100%	✓	Meets Mandate	
Physical Inspection	100%	✓	Meets Mandate	
Air Filter Change (MERV-8)	100%	✓	Meets Mandate	
Air Filter Upgrade (MERV-13)	100%	✓	Exceeds	Filters to be received 8/25, filters to be changed 8/25
24 - hour Air Flushout	100%	✓	Exceeds	
Flush All Toilets	100%	✓	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	✓	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	✓	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	✓	Meets Mandate	
Occupancy Reduced	100%	✓	Exceeds	Athletics has plan for occupancy reduction
Disinfected Before Occupancy	100%	✓	Exceeds	
Hand Sanitizer Installed	100%	✓	Meets Mandate	
Building Circulation Plan	100%	✓	Exceeds	
UV Light Analysis	100%	✓	Exceeds	Not Recommended
AtmosAir Analysis	100%	✓	Exceeds	Not Recommended

Goldstein Academic				
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	System Checked and Working
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Signage completed
Office Occupancy Reduced	N/A	<input checked="" type="checkbox"/>	Exceeds	Office Occupancy Responsibility of Department
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Goldstein Health and Fitness				
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	100%	<input checked="" type="checkbox"/>	Exceeds	
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis

Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Athletics has plan for occupancy reduction
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	20%	<input type="checkbox"/>	Exceeds	Recommended Areas Submitted
Kessel Campus Center		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Chartwell's plan for cafeteria reduction
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	

Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	20%	<input type="checkbox"/>	Exceeds	Recommended Areas Submitted
Approve Chartwells Plan	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Miller Hall		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Signage completed
Classroom Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Red/Green System in place
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Mortola Library		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	

Air Filter Change (MERV-8)	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	<div style="width: 10%;"><div style="width: 10%;"></div></div> 10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Occupancy Reduced	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Disinfected Before Occupancy	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	<div style="width: 25%;"><div style="width: 25%;"></div></div> 25%	<input type="checkbox"/>	Exceeds	On Hold
Plexiglass Shields Installed	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	<div style="width: 50%;"><div style="width: 50%;"></div></div> 50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	<div style="width: 20%;"><div style="width: 20%;"></div></div> 20%	<input type="checkbox"/>	Exceeds	Recommended Areas Submitted
Willcox		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Cooling Issues on AC-1 - AC5
Physical Inspection	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	<div style="width: 10%;"><div style="width: 10%;"></div></div> 10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Flush All Toilets	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Installation 8-11

Classroom Occupancy Reduced	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	Red/Green System in place
Disinfected Before Occupancy	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	<div style="width: 50%;"><div style="width: 50%;"></div></div> 50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	<div style="width: 20%;"><div style="width: 20%;"></div></div> 20%	<input type="checkbox"/>	Exceeds	Recommended Areas Submitted
Alumni		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	System Checked and Working
Physical Inspection	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	<div style="width: 10%;"><div style="width: 10%;"></div></div> 10%	<input type="checkbox"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	Building Runs 24/7
Flush All Toilets	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	<div style="width: 50%;"><div style="width: 50%;"></div></div> 50%	<input type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Occupancy Reduced		<input type="checkbox"/>	Exceeds	
Disinfected Before Occupancy	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
Plexiglass Shields Installed	<div style="width: 100%;"><div style="width: 100%;"></div></div> 100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	<div style="width: 50%;"><div style="width: 50%;"></div></div> 50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	<div style="width: 20%;"><div style="width: 20%;"></div></div> 20%	<input type="checkbox"/>	Exceeds	Recommended Areas Submitted

Heat Recovery Wheel Disabled		<input type="radio"/>	Meets Mandate	
Elm Hall		<input type="radio"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	System Checked and Working
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Change (MERV-8)	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Air Filter Upgrade (MERV-13)	10%	<input type="radio"/>	Exceeds	Filters not yet received, will be installed ASAP
24 - hour Air Flushout	100%	<input checked="" type="checkbox"/>	Exceeds	Building Runs 24/7
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	50%	<input type="radio"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Occupancy Reduced		<input type="radio"/>	Exceeds	
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	50%	<input type="radio"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	20%	<input type="radio"/>	Exceeds	Recommended Areas Submitted
Heat Recovery Wheel Disabled		<input type="radio"/>	Exceeds	
Martin Hall		<input type="radio"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	BMS Controls Heating, Currently functioning - must be rechecked in October.
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis

Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
North Hall		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	BMS Controls Heating, Currently functioning - must be rechecked in October.
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furthest Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
UV Light Analysis	50%	<input type="checkbox"/>	Exceeds	Electrical Installation for UVC Completed
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Town Houses		<input type="checkbox"/>		
BMS Check - Mechanical Equipment	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis

Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	N/A
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	No signage required
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	N/A
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Art Studio		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Signage Installation 8/13
Classroom Occupancy Reduced	100%	<input checked="" type="checkbox"/>	Exceeds	Red/Green System in place
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	25%	<input type="checkbox"/>	Exceeds	On Hold
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Buchsbaum		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis

Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Signage Installation 8-13
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	On Hold
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Environmental Center Complex		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Gannet Complex		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Signage Installation 8-13

Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Vineyard		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Installation 8-13
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Welcome Center / Marks Hall		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Installation 8/14

Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Applicable
Plexiglass Shields Installed	100%	<input checked="" type="checkbox"/>	Exceeds	Initial Order Fulfilled
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Wright Cottage		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Installation 8/13
Disinfected Before Occupancy	0%	<input type="checkbox"/>	Exceeds	
Hand Sanitizer Installed		<input type="checkbox"/>	Meets Mandate	
Building Circulation Plan	25%	<input type="checkbox"/>	Exceeds	On Hold
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
99 Castleton		<input type="checkbox"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	Completed on a weekly Basis
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Not Required
Disinfected Before Occupancy		<input type="checkbox"/>	Exceeds	

Hand Sanitizer Installed		<input type="radio"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	Not Required
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recmmended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Reccommended
Coordinate with Building Owner		<input type="radio"/>	Meets Mandate	
100 Summit - Valhalla		<input type="radio"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Run Water Fountains / Bottle Fillers	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	Installation 8-14
Disinfected Before Occupancy	100%	<input checked="" type="checkbox"/>	Exceeds	
Hand Sanitizer Installed	100%	<input checked="" type="checkbox"/>	Exceeds	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Coordinate with Building Owner	100%	<input checked="" type="checkbox"/>	Meets Mandate	Building Owner Has Upgraded to MERV-13 Filters and will run HVAC to ASHRAE recommendations
Thalle		<input type="radio"/>		
Physical Inspection	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Flush All Toilets	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Run Furtherst Faucet on Every Floor	100%	<input checked="" type="checkbox"/>	Meets Mandate	
Run Water Fountains / Bottle Fillers		<input type="radio"/>	Meets Mandate	Run Bottle Fillers / Lockout Water Fountains
Signage in Place	100%	<input checked="" type="checkbox"/>	Meets Mandate	No signage required
Disinfected Before Occupancy		<input type="radio"/>	Exceeds	

Hand Sanitizer Installed		<input type="radio"/>	Meets Mandate	
Building Circulation Plan	100%	<input checked="" type="checkbox"/>	Exceeds	No signage required
UV Light Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not recommended
AtmosAir Analysis	100%	<input checked="" type="checkbox"/>	Exceeds	Not Recommended
Coordinate with Building Owner		<input type="radio"/>	Meets Mandate	